

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SP7

Dated: 18/4/24

It is certified that an inspection team headed by Manoj Kumar Prasad

(Name of Officers with designation) from AEN PHED DIV BTP

inspected the Morden School Bharatpur

(Name & Address of the school) on 18/4/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Lab/Peel/2024-25-9495 dated 18/4/24

of Distt (PHED Lab) certified that

the Morden School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 3/03/25

Signature with Seal: MUML 18/4/24

Name

Designation

Name & Address of the Office / Department

To MODERN SCHOOL BHARATPUR

MAHARAJA ROAD NAHLA KIDHARI

(Name & Address of the Institution) POST BHARATPUR

BHARATPUR 321001

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

OFFICE OF THE SENIOR CHEMIST, PHED LABORATORY, BHARATPUR

REPORT OF THE CHEMICAL EXAMINATION

No.: Lab/ Tech/ 2024 -2025/ 94

Date: 18/4/24

To,

Principal
Modern School, Bharatpur
Bharatpur

DISTRICT: BHARATPUR
TEHSIL: Bharatpur

This Sample was not
Collected by Lab.

REFERENCE:- YOUR LETTER NO
DATE OF RECEIPT: -

Nil/16.4.2024
16.4.2024

Sample Taker :-
Date of Examination: -

Sh. Kehari Singh
16.04.2024

Source Type	R/O	PERMISSIBLE VALUE AS PER BIS; 10500-2012	
Location of Source	Modern School NH-21 Agra Road Bharatpur		
Village/Habitation	Bharatpur	Desirable Limit	Permissible limit in absence of alternate source
Date of Collection:	16.4.2024		
Lab Sample No.	52		
Note: - All Results except pH are in mg/L			
1. pH	7.0		
2. Turbidity (NTU)	Clear	6.5 - 8.5	6.5 - 8.5
3. Colour	0.0	1	5
4. Odour	N.D.	5	15
5. Total Alkalinity(as CaCO ₃)	30	Agreeable	Agreeable
6. Total Hardness (as CaCO ₃)	20	200	600
7. Calcium Hardness (as CaCO ₃)	10	200	600
8. Magnesium Hardness (as CaCO ₃)	10	-	-
9. Chloride (as Cl ⁻)	50	250	1000
10.Sulphate (as SO ₄)	-	200	400
11.Nitrite (as NO ₂)	-	-	-
12.Nitrate (as NO ₃)	1	45	No Relaxation
13.Fluoride (as F ⁻)	0.09	1.0	1.5
Total Dissolved Solids	126	500	2000
Iron	-	0.1	1.0
16.Residual Chlorine	-	0.2	2.0

No.: Lab/ Tech/ 2024-2025/

Copy to: -

1. The Chief Chemist, PHED Rajasthan, Jaipur.

Senior/Junior Chemist
PHED Lab, Bharatpur

Date:-

Senior/Junior Chemist
PHED Lab, Bharatpur

Confidential

OFFICE OF THE SENIOR CHEMIST, PHED LABORATORY, BHARATPUR
BACTERIOLOGICAL EXAMINATION REPORT OF WATER

No.: Lab/ Tech/ 2024-2025/ 35
To,

Principal
Modern School Bharatpur,
Bharatpur

Date: - 18/4/25

DISTRICT: - Bharatpur
TEHSIL: - Bharatpur

*The Sample was not
collected by Lab.*

REFERENCE:- YOUR LETTER NO.: -Nil/ 16.04.2024

Collect by:- Sh. Kehari Singh

Sample No.	Date & Time of Collection	Date of Examination	Residual Chlorine (mg/L)	Particulars of Samples	Coliform Organism MPN per 100 ml.	Remark
126	16.04.2024	16.04.2024	0.0	R/O Water, Modern School NH-21 Agra Road Bharatpur	Nil	Satisfactory

AS 3/4/2024
Senior/Junior Chemist
PHED Lab, Bharatpur

No.: Lab/ Tech/ 2024-2025/
Copy to: -

Date:-

1. The Chief Chemist, PHED Rajasthan, Jaipur.

~~Senior/Junior Chemist
PHED Lab, Bharatpur~~